



NOTES

1. IT IS THE RESPONSIBILITY OF THE CONSULTANT OR CONTRACTOR, TO CONFIRM THAT THE CONTROLS SELECTION IS CORRECT PRIOR TO INSTALLATION.
2. DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS SHOULD BE CHECKED ON SITE.
3. THIS DRAWING IS FOR INDICATION ONLY.
4. ALL CONTROLS COMPONENTS SHOULD BE FITTED INSIDE A SUITABLE ENCLOSURE.
5. ALL CABLES MUST BE SIZED ACCORDING TO CURRENT

LEGEND

- | | |
|----|-------------------------------|
| 1 | Live Wire on Indoor Unit |
| 2 | Neutral Wire on Indoor Unit |
| 3 | Serial Wire on Indoor Unit |
| L | Live Wire on Outdoor Unit |
| N | Neutral Wire on Outdoor Unit |
| AB | Remote Controller Connections |

	Drawing Prepared For	Title CDL-BMS01 LEAD CONNECTED TO INDOOR UNIT TO PROVIDE RUN SIGNAL OUTPUT	
	Cool Designs Ltd North Hyllon Enterprise Park Hopton Rd Sunderland SR6 3JT Tel: 0191 549 0994 Fax: 0191 549 0999 email: cdcs@cooldesigns.co.uk	Project STANDARD ELECTRICAL SCHEMATIC SHOWING CDL-BMS01 LEAD CONNECTED TO DI SPLIT TO PROVIDE RUN SIGNAL OUTPUT	Drawn By Scale NTS
		Drawing No.	