



TOSHIBA INVERTER SYSTEM R410a

NOTES

1. IT IS THE RESPONSIBILITY OF THE CONSULTANT OR CONTRACTOR, TO CONFIRM THAT THE CONTROLS SELECTION IS CORRECT PRIOR TO INSTALLATION.
2. DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS SHOULD BE CHECKED ON SITE.
3. THIS DRAWING IS FOR INDICATION ONLY.
4. ALL CONTROLS COMPONENTS SHOULD BE FITTED INSIDE A SUITABLE ENCLOSURE.
5. ALL CABLES MUST BE SIZED ACCORDING TO CURRENT WIRING REGULATIONS.

LEGEND

- | | |
|------|-------------------------------|
| 1 | Live Wire on Indoor Unit |
| 2 | Neutral Wire on Indoor Unit |
| 3 | Serial Wire on Indoor Unit |
| L | Live Wire on Outdoor Unit |
| N | Neutral Wire on Outdoor Unit |
| A, B | Remote Controller Connections |

TOSHIBA
AIR CONDITIONING

Toshiba Air Conditioning
United Technologies House
Guildford Road, Leatherhead
Surrey, KT22 9UT
Tel: 01372 220 266 Fax: 01372 220 267
email: projects.toshiba-ac@toshiba-ac.com

Drawing Prepared For				
Project GENERIC SCHEMATIC		Rev	Date	Description
Title STANDARD ELECTRICAL SCHEMATIC D/SDI WITH RBC-TS11 & D BUS CONNECTIONS FOR RUN AND STANDBY AND DUTY SHARING		Drawn By	Checked By	
		Scale	Date Drawn	
		NTS	04/08/2017	
	Drawing No.	TDN.10E-09		Rev A